



KERB

150 THICK CAST INSITU 32MP<sub>a</sub> CONCRETE LAID WITH F62 REINFORCEMENT 50mm FROM BOTTOM. CONCRETE TO BE LAID ON A COMPACTED SUBGRADE

OR

30mm BC (ASPHALT) ON A 300mm GRAVEL OR CRUSHED ROCK BASE COURSE WITH 300 X 200 FLUSH KERB

## MINIMUM STANDARD FOR INDUSTRIAL CROSSOVER



**shire of  
kalamunda**

DEPARTMENT  
OF  
ENGINEERING SERVICES

TITLE:

**TYPICAL CROSSOVERS  
INDUSTRIAL CROSSOVER**

DRN: **G LAWRENCE**

DATE: **20/03/2007**

AUTHORISED:

SCALE: **NOT TO SCALE**

INIT: DATE:

DWG NO:

**3/3**